



## Key Switch

- \* One Motor
- \* One Key Switch

### *Reference Numbers*

- 601200 - Maintained key switch, surface mount
- 601202 - Maintained key switch, recessed mount

**NOTICE:** For installation by a qualified electrician in accordance with national and local electrical codes, and the following instructions.

**CAUTION: RISK OF ELECTRICAL SHOCK.** Disconnect power before installing. Never wire energized electrical components.

Select conductors having 90°C or higher rated insulation having sufficient ampacity in accordance with the 60°C column of National Electrical Code® Table 310-16 or Canadian Electrical Code Table 2

DO NOT USE TIN CONDUCTORS.

### **Warning**

**DO NOT** wire more than one operator to a single pole switch. A second operator can be wired to the second pole of a double pole switch.

**DO NOT** connect two switches to an operator without a relay.